

INDIANA UTILITY REGULATORY COMMISSION 101 W. WASHINGTON STREET, SUITE 1500E INDIANAPOLIS, INDIANA 46204-3407 http://www.in.gov/iurc Office: (317) 232-2701 Facsimile: (317) 232-6758

Pipeline Safety Division Investigation Report

Investigation regarding: McAllister General Contractors

UPPAC Database Record ID: 4034

Investigator: Howard Friend

Report Date: 3/13/13

The Parties

Excavator: McAllister General Contractors

Contact: Christopher McAllister, Vice President

Address (City, State): PO Box 810, Cedar Lake, IN 46303

Telephone: 219-374-9498

Facility Owner Information:

Business Name: NIPSCO

Synopsis: A natural gas facility was damaged during excavation for drainage.

Findings: The excavator had a valid locate request however, the operator failed to provide accurate locate markings. The operator did not have any records of this facility.

Conclusion: There was a failure to provide accurate locate markings.

Violation: IC 8-1-26-18(f): Operator failed to locate the facility.